



United States Department of State

American Embassy Khartoum

To: Prospective Quoters

August 5, 2018

Subject: **Request for Quotations No. 19SU4018Q0010**

The Embassy of the United States of America invites eligible suppliers to submit a quote to supply and deliver one (1) 250 KVA Automatic Voltage Regulator.

Specifications:

Automatic Voltage Regulator Stabilizer Orion Plus – ORTEA or Equal

Item	Description	Quantity	Required Generic Characteristics	Price \$
1	250 KVA Automatic Voltage Regulator Stabilizer Orion plus 250 KVA Origin ORTEA Italy Or Equal	1	Type: 250-50 Input Voltage Variation Range (%) : +25 Rating (KVA): 250 Input Voltage Range (V): 300-500 Maximum Input Current(A): 481 Output Voltage + 0.5% (V): 400 Output Current (A): 361 Efficiency (%): 98 Speed Regulation ms/V: 12 Cabinet (Type): 55 Weight (Kg): 1300	

Delivery Location and Time: The contractor shall deliver all ordered items to the U.S Embassy Khartoum no later than 30 days from receipt of a contract.

The address is: American Embassy Khartoum, Block 088, Kilo 10, Soba, Khartoum, Sudan

The due date and time for this RFQ is August 20, 2018@ 16.00 hours, Khartoum local time (GMT+2). Please submit your offers by e-mail to gedieag@state.gov and cc sulimanaa@state.gov OR submit a sealed envelope to the American Embassy Khartoum, Soba, kilo10.

The U.S. Government intends to award a contract to the responsible company submitting the lowest priced technically acceptable quote. The Government intends to award a contract based on initial quotes, without holding discussions, although we may hold discussions with companies in the competitive range if there is a need to do so.

For queries, please contact Alganesh Gedie at Tel: (249)-1-870-22019; or email: gedieag@state.gov.

Sincerely,

John Everman
Contracting Officer